



1 x 9290037905 2700k 1.9w
1 x 220 lm

Polar intensity diagram



Quantity estimation diagram



Light output ratio 1.01
Service upward 0.48
Service downward 0.53

CIE flux code 14 38 68 52 101

Utilisation factor table

Room Index k	Reflectances (%) for ceiling, walls and working plane (CIE)															
	0.80 0.80				0.70 0.70 0.70 0.70				0.50 0.50				0.30 0.30		0.00	
	0.80	0.80	0.50	0.50	0.50	0.50	0.50	0.30	0.30	0.10	0.30	0.10	0.10	0.10	0.10	0.10
0.60	0.32	0.31	0.29	0.29	0.28	0.20	0.17	0.12	0.13	0.10	0.04					
0.80	0.41	0.39	0.37	0.36	0.35	0.27	0.22	0.17	0.18	0.14	0.07					
1.00	0.48	0.45	0.44	0.42	0.41	0.33	0.27	0.22	0.22	0.17	0.09					
1.25	0.56	0.51	0.51	0.49	0.47	0.39	0.32	0.27	0.26	0.21	0.12					
1.50	0.62	0.56	0.56	0.54	0.51	0.43	0.36	0.31	0.29	0.25	0.15					
2.00	0.71	0.63	0.64	0.61	0.58	0.51	0.43	0.37	0.35	0.31	0.19					
2.50	0.77	0.68	0.70	0.66	0.63	0.56	0.47	0.42	0.39	0.35	0.23					
3.00	0.82	0.72	0.74	0.70	0.66	0.60	0.51	0.46	0.42	0.38	0.25					
4.00	0.89	0.77	0.81	0.76	0.71	0.66	0.56	0.52	0.46	0.43	0.29					
5.00	0.94	0.80	0.85	0.79	0.74	0.70	0.59	0.56	0.49	0.46	0.32					

Ceiling mounted

Luminance Table

Plane Cone	0.0	15.0	30.0	45.0	60.0	75.0	90.0
45.0							
50.0							
55.0							
60.0	Cannot draw luminance table: the apparent area equals zero.						
65.0							
70.0							
75.0							
80.0							
85.0							
90.0							

(cd/m²)

2024-04-19